


QUANTAL




V2 | November 2019

ROOF VENT INSTALLATION GUIDE

CONTENTS

section 1	Components list	2
section 2	Roof vent sash	3
section 3	Vent main frame into roof	3-4
section 4	Fitment of mechanical winder	4-5
	Fitment of electric motor (if selected)	5
section 5	Installation of vent controller	6
	Optional automatic vent controller	6
section 6	Switch and controller wiring	7
section 7	Installation of rain sensor	7
section 8	Adjustment and testing	8
section 9	Use of controller	8

**TECHNICAL SUPPORT**

Tel: 01200 414618 Email: techsupport@quantal.co.uk

Please read in conjunction with the installation guide provided with the roof itself.

COMPONENT LIST - (DEPENDANT ON ANCILLARIES CHOSEN)

SECTION 1

SLIMLINE 25MM ROOF VENT



SPINDLE - SLVSP001





ROOF VENT POLE BRPA001



SLVTS002-6 - VENT SCREW




TAPE

PMB/2
INTERNAL (STANDARD)AMB-/25
EXTERNAL (STANDARD)AMB-/32
EXTERNAL (35MM GLAZING)AVS001
ROCKER SWITCH*SLCCU003
RADIO CONTROL UNIT*SLRCU003RC
REMOTE CONTROL*SLCCU002
THERMOSTAT & DIGITAL
RAIN SENSOR*MOTOR*
White Q8750
Black QBL8750AVTD002
THERMOSTAT &
ANALOG RAIN SENSOR*

*separate installation guide supplied in box.


ROOF VENT SASH

SECTION 2




Unwrap the sash and pull two side sections out as shown above.


Remove any protective handling tape around the perimeter of the unit prior to installation.




Apply length of foam tape directly to the lower edge of the outer pane of the glass unit as shown. Start by applying the tape 70mm up the side of the glass unit and continuing to wrap around the lower edge of the glass unit, finishing 70mm up the opposite side.



For pitches below 10° it is recommended that the glass is sealed in by running a bead of silicone along the length of each sash section as shown above. For pitches above 10° it is advisable to do the same.




Once tape has been applied, assemble the sash in the sequence shown above and ensure the tape is directed against section 2.



If the pre-drilled holes appear out of alignment as shown above in red simply slacken off the factory fitted screws.



The two sections can then be readjusted so they are in line and square. Then the non factory fitted screws can be fixed down.



Finally re-fasten the factory fitted screws.




On the hinge side of the sash fill the hole shown above at either end with a blob of silicone.


NOTE The roof vent has been successfully tested by the BBA at 25° up to 1200Pa without sealant.

VENT MAIN FRAME INTO ROOF

SECTION 3




Peel back any protective film prior to fitting. Fit upper glazed unit and internal muntin bar. Carefully lower the vent frame into position onto the internal upper muntin bar.





Ensure the vent is central between the transoms. As shown above there should be a 13mm gap between the bar centre and the frame. Use glazing packers if necessary.




If existing glazing is 32/35mm a packer will have been pre-fitted to the frame.





Run a bead of appropriate sealant ensuring a continuous run along the external upper muntin bar. Please see section view for bead positioning.




Locate the external upper muntin bar with the internal muntin bar, knock into place. The lower muntin may need to be supported from underneath whilst secure into final position.





Slide the internal lower muntin bar into place under the vent frame. See cross section 9a for further detail.



Remove any handling tape around the perimeter of the unit. Take care lowering the glazed unit into position on the internal lower muntin bar.




Run a bead of appropriate sealant ensuring a continuous run along the external lower muntin bar. Please see cross section for bead positioning.




Locate the external lower muntin bar with the internal lower muntin bar, knock into place. The lower muntin may need supporting from underneath whilst secured into final position.

FITMENT OF MECHANICAL WINDER

SECTION 4




When the sealant on the mainframe has cured, re-fit the outer sash by holding vertically and re-engage on to the hinge, before lowering into position.




Using the screws provided attach the spindle bracket to the sash bracket (already attached to vent sash) taking care not to damage the glazed unit.



Align the winder bracket with bottom of vent frame (see section detail 15a for further information). Centrally align the winder bracket with the sash bracket. Once in position securely fit bracket in place using screws provided.



Attach the winder head to the sash bracket, using the plunger pin. Hold the winder at the relevant angle. Turn the winder body clockwise until it locks with the sash bracket.




Apply downward force to the sash bracket (see 1). Turn the connection collar until the holes on the collar are approximately 3mm above the holes in the winder bracket (see 2). Holding the connection collar in place, turn the winder body anti-clockwise to loosen the sash bracket. This will enable you to fit the holding bolts without affecting the winder set-up.

FITMENT OF ELECTRIC MOTOR (IF SELECTED)


SECTION 4



Using the nuts and bolts provided attach the motor bracket to the sash bracket taking care not to damage the glazed unit.



Align motor brackets vertically using the extrusions details as shown.



Mark out as shown above from edge of sash bracket to edge of motor bracket. Then mark the holes using the motor bracket as a template. Use a 2.5mm drill bit to pilot drill through the frame.



Secure the brackets to the frame using screws provided.



Fit provided securing bolts into the motor body through the location holes in the brackets.



Finished mounted motor in situ.

Note: For further details, refer to motor instruction guide which can be located in the motor box.

INSTALLATION OF VENT CONTROLLER

SECTION 5

THIS UNIT MUST BE INSTALLED BY A QUALIFIED ELECTRICIAN TO THE 17th EDITION BS7671 REQUIREMENTS FOR ELECTRICAL INSTALLATIONS

1. Remove the front panel by loosening the retaining screws.
2. Screw the back box to the surface of a masonry wall in the conservatory, at the usual height of a wall switch.
3. Choose appropriate knock out for cable entry and smooth edges to prevent damage to cable insulation.
4. In any situation where the mains cable is not plastered into the wall, the cable must be adequately secured as close as possible to the control box to prevent undue stress on the cable.
5. Connect the cables in accordance with the wiring diagram, bringing sheath as close as possible to the terminal blocks, to prevent contact of the inner insulation with other parts of the p.c.b. Note that a junction box will be required in the ridge, to bring all the actuator cables together. Run a single four-core cable from here to the control box. Note that a fused isolator must be installed, providing a contact separation of at least 3mm in all poles.
6. Replace the front panel.


THIS UNIT TO BE INSTALLED USING BASEC OR HAR APPROVED CABLE, AND MUST BE SUITABLY EARTHED
NOTE: CABLE NOT SUPPLIED BY QUANTAL

OPTIONAL AUTOMATIC VENT CONTROLLER

SECTION 5

NOTE: CABLE NOT SUPPLIED

The Automatic Vent Controller is an integrated electronic thermostat and controller with rain sensor, for automatic and manual operation of motorised roof vents. The vents open automatically at high temperatures and close again when the temperature drops or rain is detected. Up to 6 Quantal actuators can be controlled by type Q8750.



TECHNICAL SPECIFICATION

Mains Supply: 230V 5A 50Hz

Output current to actuators: 5.2A max at 20% duty cycle

Opening impulse: Variable, 3 to 9 sec approx.

Closing impulse: 11 sec approx

Differential temp of thermostat: 2°C

Mounting angle of rain sensor: 15° to 45°

Cable for rain sensor: 0.5mm² 2 core round flexible cable. Ø5 to 7mm

Working voltage of rain sensor: 1V to 6V wet - 7.5V to 10V dry (a.c.)

Equivalent resistance of rain sensor: Less than 80k ohms wet. Greater than 300k ohms dry

Finish: White only


Dimensions of controller: 148 x 88 x 52 excluding thermostat setting knob

Dimensions of rain sensor: 75 x 51 x 28 excluding cable gland

Weight of combined units in packing carton: 450g

SWITCH AND CONTROLLER WIRING

SECTION 6



INSTALLATION OF RAIN SENSOR

SECTION 7

1. Pass the cable through the cable gland, strip the cable ends and crimp on the terminals supplied.


2. Push the terminals on to the blades. Do not over tighten the nuts and screws, or the conductive pattern may be damaged by indentation.

NOTE: Round 3A mains cable must be used to ensure that the cable gland grips the cable and forms a waterproof seal. (This cable carries only 9V a.c. however).


3. Fit the bottom cover without sealing the joint

4. Attach the unit with the self-adhesive pad provided to a convenient exposed part of the roof, with the black sensing pattern uppermost. The cable can point towards the ridge, gutter, or to either side. The unit must slope at a gradient of at least 15° to enable excess water to run off. Packing may be required on a lean-to roof to ensure this. Avoid shelter from overhanging eaves, especially if the conservatory is on the sheltered side of a taller building (house etc). In the UK the prevailing wind and most rainfall comes from the South-West. This is therefore the preferred side of the roof for the rain sensor, but check local conditions, especially on the East Coast or on Mainland Europe.

15° to 45° PITCH



PACKING WHEN PITCH IS LESS THAN 15°



Rain Sensor Mounting Position

Call: 01200 414604
Email: info@quantal.co.uk

QUANTAL

Quantal's policy is one of continuous development and specification and ranges may change without notification.

www.quantal.co.uk
Job No. 5063 11/19.
Code: SLVQIG001